



Qualifying Your Sales Establishment Vendor Checklist



Storage



Display



Sale

<input type="checkbox"/>	The building and its storage units do not exceed 1,000 kg of fireworks. If the building contains a dwelling, it does not exceed 100 kg of fireworks.	<input type="checkbox"/>	All fireworks are separated into lots of 25 kg or less.	<input type="checkbox"/>	Vendors must offer buyers a copy of the table that describes safety instructions for using consumer fireworks or a document that contains the same information.
<input type="checkbox"/>	All fireworks are stored at least 100 m from above ground storage tanks for flammable substances in bulk.	<input type="checkbox"/>	Each lot is separated sufficiently enough to prevent fire from spreading rapidly from one lot to the next.	<input type="checkbox"/>	Fireworks cannot be sold to anyone less than 18 years of age.
<input type="checkbox"/>	All fireworks are stored at least 8 m from fuel dispensers at a fuel dispensing station; retail propane-dispensing tanks and cylinders; dispensing facilities for compressed natural gas.	<input type="checkbox"/>	All fireworks are kept away from accelerants and are not exposed to the sun, moisture or excess heat.	<input type="checkbox"/>	Any sale over 150 kg must be kept record of for 2 full years from the date of purchase. You must keep the buyers <u>name</u> , <u>address</u> (operator <u>licence info</u> if applicable), <u>products names</u> and <u>company of authorization</u> , the <u>quantity</u> of each product, if the products were <u>sold for resale or use</u> and the <u>date</u> .
<input type="checkbox"/>	The storage facility displays a warning sign marked "fireworks"	<input type="checkbox"/>	Fireworks are either in a consumer pack or locked away and inaccessible to the public.		
<input type="checkbox"/>	Fireworks are not stored in vehicles of any kind.	<input type="checkbox"/>	Smoking is prohibited within 8 m of fireworks.		
<input type="checkbox"/>	If a sales establishment is temporary, retailers must ensure that all fireworks are stored at least 8 m from combustible materials, sources of ignition, thoroughfares, buildings or other temporary sales establishments; all fireworks are stored at least 3 m from any vehicle parking area; and if the temporary sales establishment is a tent, the tent is made from flame-retardant material.	<input type="checkbox"/>	Fireworks are separated from the ceiling and from any fire prevention system by at least 0.6 m.		